

**OSHA Testing Requirements
1910.137, 1910.269, ANSI A92.2**

Personal Protective Equipment Testing Intervals

Type of Equipment	When to test
Rubber insulating line hose	Upon indication that insulating value is suspect
Rubber insulating covers	Upon indication that insulating value is suspect
Rubber insulating blankets	Before first issue and every 12 months thereafter
Rubber insulating gloves	Before first issue and every 6 months thereafter
Rubber insulating sleeves	Before first issue and every 12 months thereafter
Live Line Tools	2 year cycle

